

Executive Engineer, Construction Division No.3,

P. W. D. (B&R) Br., Batala Road, Amritsar

E-mail:- xencw2amritsar@gmail.com

To

The Principal,
Learning Passion School,
School Lane, Garden Avenue,
Bypass Road Ajnala, Distt. Amritsar.

No.

3791

Dated:

21-11-25

Subject: Building Safety Certificate for the year 2025 to 2026.
(Learning Passion School Lane, Garden Avenue, Bypass Road Ajnala Distt. Amritsar).

Reference: Your office letter no.Nil dated: 03.10.2025.

Sub Divisional Engineer, Construction Sub Division Ajnala vide his letter No.154 dated: 17.11.2025 has reported this office that the building of "Learning Passion School Lane, Garden Avenue, Bypass Road Ajnala Distt. Amritsar " has been visually inspected and found the same provisionally fit for human inhabitation for the One year 2025-26 i.e. upto 31.03.2026. Your application for safety certificate will only be considered when you will fulfill all requirement under column 14 of Performa Part-I.

DA/Performa I & II

Executive Engineer,
Construction Division No.3,
P.W.D. (B&R) Br., Amritsar.

For Learning Passion School

Manager

Endst.No. _____

Dated: _____

A copy of above is forwarded to Sub Divisional Engineer, Construction Sub Division Ajnala, P.W.D. (B&R) Br., Amritsar w.r.t. his letter No.154 dated: 17.11.2025 for information and necessary action.

D.A./Nil

Learning Passion School, Ajnala

Principal

Executive Engineer,
Construction Division No.3,
P.W.D. (B&R) Br., Amritsar.

**PROFORMA FOR THE SAFETY CERTIFICATE OF SCHOOL BUILDING
(PART-I)**

(To be filled in by the head of school, institute)

1. Name of the School **LEARNING PASSION SCHOOL**
2. Location **GARDEN AVENUE, AJNALA**
3. Plot Area
4. Covered Area of Building **10040 SQ. FT. ✓**
5. Number of Stories **TWO ✓**
6. Year of Construction **2022 ✓**
- a) Frame Structure **YES**
- b) Brick masonry structure
7. If the building has been constructed under the supervision of the qualified Engineer, the following details may be given:- **YES**
- a) Name of Engineer with qualification **MR. RIPUDAMAN SINGH**
- b) Address of the Engineer **BYPASS ROAD, AJNALA**
- c) If structural drawing used in the construction, if available? **YES**
- d) Name and address of Architect with qualification **RIPUDAMAN SINGH (BARC, MTECH)**
8. Whether the building has been constructed for the purpose of
- a) School **✓ Yes/ No**
- b) Residential purpose and used for a school **Yes/No**
9. Materials used for Roofs **RCC SLABS**
- a) R.C.C.Slabs
- b) R.S.Joists & Battons
- c) Wooden Joints and bottom
10. Material used for Walls
- a) Mud Mortar **Yes/No**
- b) Cement Mortar **✓ Yes/No**
- c) Lime Mortar **Yes/No**
11. Flooring
- a) Conglomerate **Yes/No**
- b) Terrace **✓ Yes/No**
- c) Brick Paving **Yes/No**
12. A detailed drawing indicating the doors along with windows and location fitting and windows is attached. **YES**
13. FOR FIRE SAFETY
- a) Whether the width of the staircase is 1.5 mtr. **✓ Yes/No**
- b) Whether portable fire extinguisher exists **✓ Yes/No**
- c) Whether School building is free from inflammable & toxic material **✓ Yes/No**
- d) Whether cooking of food is done at a safe place **✓ Yes/No**
- e) Whether any Thatch or combustible material has been used **Yes/No ✓**

14. Requirement for Fire Protection Arrangements under

For Learning Passion School
[Signature]
Manager

Learning Passion School, Ajnala

[Signature]
Principal



Part-IV

Building height less than 15 metre)

- | | |
|--|--------|
| a) Whether Hose Real provided | Yes/No |
| b) Whether down comer provided | Yes/No |
| c) Whether Automatic sprinkler provided | Yes/No |
| d) Whether underground static water storage tank of capacity 50000 Ltr.(if converted area exceeds 1500 sqm) | Yes/No |
| e) Whether over head tank of capacity 10000 Ltr.exists (in case of hose real) 20000 Ltr. | Yes/No |
| f) Whether one eclectic and one diesel pump of 3 kg/cum Pressure of capacity 1620 LPM, one electric pump of Capacity 180 LPK exist near underground static tank. | Yes/No |
| g) Whether a pump 3 kg/cum pressure & 450/500 LPM Exist near over head tank. | Yes/No |

Signature of the Head of School/Institute



PART-II

(To be filled by the SDE of PWD (B&R) Department)

- a) I have visited the above mentioned school on dated 12/11/2025 and have visually inspected it from all angles of safety and find it fit for normal use as school building.
- b) In case any addition/alteration or expansion and modifications to this buildings is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.
- c) In case the building is affected by flood, or if there is settlement of walls/ foundations or sagging of roofs etc. immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) This building can be safely occupied for normal use upto (indicate upto which it can be used)
1 year 2025-26

For Learning Passion School
[Signature]
Manager

Learning Passion School, Ajnala

[Signature]
Principal

[Signature]
Sub-Division Engineer
Construction Sub-Division,
PWD (B&R), Ajnala.